



City of Concord, New Hampshire

PURCHASING DEPARTMENT

CITY HALL, 41 GREEN STREET

CONCORD, NH 03301

(603) 225-8530

FAX: (603) 230-3656

October 4, 2006

ADDENDUM NUMBER TWO

B21-07

BOILER REPLACEMENTS, CONCORD, NEW HAMPSHIRE

TO ALL FIRMS OF RECORD: This addendum forms a part of and modifies the bidding and contract documents and technical specifications for the project named above. The following changes, additions and clarifications are made to the original Contract Documents:

Miscellaneous questions and responses:

1. **Space Limitations:** The utility closets in the Mast Yard West property have limited area in which to install a non-power vented boiler. The closets measure approximately 2 ft. x 4 ½ ft. Because these utility closets are interior to the typical unit floor plan, it will be impractical to use a power vented replacement boiler. Due to the space limitations and required code clearances for a new boiler, bidders are advised that a combined boiler with indirect fired water heater or a 4-port water heater with a flat plate heat exchanger may need to be specified in order to meet installation clearances. External domestic water storage tanks may need to be installed in adjacent closet spaces. The second page of this Addendum #2 shows two photographs of a typical Mast Yard West utility closet.
2. **Bid Opening Due Date/Time:** Please note the bid opening due date/time has changed from Thursday October 12, 2006 not later than 2:00pm to Tuesday October 17, 2006 not later than 3:00pm.

PLEASE BE ADVISED THAT THE CONTRACTOR MUST ACKNOWLEDGE RECEIPT OF ADDENDUM ONE AND TWO ON THEIR BID SHEET.

CITY OF CONCORD, NEW HAMPSHIRE

Douglas B. Ross

DOUGLAS B. ROSS
PURCHASING AGENT



Typical Utility closet at Mast Yard West.