



City of Concord, New Hampshire

PURCHASING DEPARTMENT

CITY HALL, 41 GREEN STREET

CONCORD, NH 03301

(603) 225-8530

FAX: (603) 230-3656

April 29, 2009

ADDENDUM NUMBER ONE

B59-09

2009 PAVEMENT RECLAMATION and SHIM OVERLAY

TO ALL FIRMS OF RECORD: This addendum forms a part of and modifies the bidding and contract documents and technical specifications for the project named above. The following changes, additions and clarifications are made to the original Contract Documents:

1. **Question:** My question is in regard to the first four bid items: 203.2 Rock Excavation, 203.36 Remove Unsuitable Material, 203.5 Borrow and 304.32 Crushed Gravel. Where is this work proposed? Page 4 of 76, description of work, only seems to describe pavement reclamation and shim/overlay items.

Answer: These items are included in case the successful contractor hits ledge or unsuitable after we have reclaimed. The borrow would be used to get to sub grade. The crushed gravel is used for the 2-foot shoulder that is required after shim and overlay and paving of the reclaim as well as to supplement the reclaimed roads if needed to get better drainage. The gravel shoulders are spelled out in both the reclamation and shim overlay descriptions.

PLEASE BE ADVISED THAT THE CONTRACTOR MUST ACKNOWLEDGE RECEIPT OF ADDENDUM ONE ON THE BID SHEET SIGNATURE PAGE (PAGE 38 OF 76).

CITY OF CONCORD, NEW HAMPSHIRE

DOUGLAS B. ROSS
PURCHASING MANAGER